



PRODUCT SPECIFICATION LPT-A-NH3 Transmitter

Analog Transmitter with Electrochemical Ammonia (NH₃) Sensors

	Standard Enclosure
Dimensions: Size	5.0" X 5.0" X 2.4" (127 mm x 127 mm x 60.96 mm) (with optional splash guard)
Weight	14 ounces (400 g)
Construction	ABS / Polycarbonate blend, water/dust tight, corrosion resistant (IP54 standard with splash guard installed)
Sensors: Type	Electrochemical
Life Span	Approximately 2-4 years (application dependent)
Gases Detected	Ammonia
Sensor Range	0 – 500 ppm standard. Other ranges available
System Power	3-wire: VDC: 12-30 VDC, 3-Watts 4-wire: VAC: 12-27VAC, 3-VA
Temperature	-20°C to +40°C (-4°F to 104°F), -40°C (-40°F) with LCD heater option
Humidity	15 to 90% non-condensing
Indicators	LCD digital display, back lit, 128 X 64 pixel graphic
Signal	Current: Linear 4-20 mA (maximum 216 ohm load, wiring plus termination resistor @ 12VDC) Maximum 316 ohm load, wiring plus termination resistor @ 12VAC Voltage: 0-10 Volt, Minimum 1k ohm load
Minimum Detection	10 ppm (with regular calibration maintenance of sensor)
Repeatability	< +/- 2% (with regular calibration maintenance of sensor)
Accuracy	+/- 10 ppm @ STP, +/- 60 ppm across measurement range at time of calibration and at calibration concentration + calibration gas concentration error
Sensitivity drift	<20% change/year in lab air (with regular calibration maintenance of sensor)
Response time	<25 seconds T ₉₀ from 0 to 400 ppm
Resolution	Display resolution 1 ppm, sensor resolution <12 ppm
Warm Up Time	5-minutes after power up (to full operation)
Cross Sensitivity	Cl ₂ 30 ppm = 5, NO ₂ 10 ppm = 6.5, SO ₂ 200 ppm = -20, H ₂ S 200 ppm = 120
Fusing	Automatic resetting thermal overload fuse (reset capabilities to 500 times)
Wiring	VDC or ground referenced VAC, 3-conductor shielded 18 awg stranded VAC 4-conductor shielded 18 awg stranded
Sensor Mounting	Lighter than air, on or near the ceiling
Monitoring Area	5000 - 7000 sq. ft.
Certifications	CSA: C22.2 NO.205-M1983 (R2009) UL: UL508 (Edition 17): 2007 CE: EMC-EN50270:2006, Type-1 & EN61000-4-2 to 11
Note	Never install gas detectors in the direct path of moving air.

Rev: 1504-2