



RELAY 1 IS COMMONLY CONFIGURED FOR LOW ALARM TRIGGERING OF A DEVICE.

RELAY 2 IS COMMONLY CONFIGURED FOR HIGH ALARM TRIGGERING OF A DEVICE.

RELAYS OPERATE IN FAILSAFE CONFIGURATION.

TWO SPDT DRY CONTACT RELAYS, INCLUDING VFD CONTROL RATED 5 AMPS @ 240 VAC

DO NOT USE SOLID CORE WIRE

NOTE: DO NOT RUN LINE VOLTAGE AND LOW VOLTAGE WIRES IN THE SAME CONDUIT.

CRITICAL ENVIRONMENT TECHNOLOGIES CANADA INC.	
NAME:	WIRING CONNECTIONS—24VAC or 24VDC POWER SUPPLY
MODEL:	All DCC Models with 1 or 2 Internal Sensors
DATE:	September 15, 2017